

THE ESTONIAN POWER SYSYEM *Future Security of Supply*

Dr Staffan Qvist

staffanq@gmail.com 2021/02/09



The current system

- The Estonian energy system is unique globally, historically based almost entirely on local oil shale (põlevkivi)
- Electricity production from oil shale (80+ % of total) is centered around the Narva power plants (Eesti, Balti, Auvere)
- Until recently, oil shale was supported as a resource for ensuring Estonia's electricity supply and energy security
- Extremely high emissions, up to 1500 gCO₂/kWh, means continued longerterm operation is untenable
- Oil shale is now shutting down, to be "replaced" mainly by imports. What are the implications for security of supply?





Ensuring security of supply

Simplified supply pathways:

Domestic dispatchable generation + Domestic variable generation + Imports



Ensuring security of supply

Simplified supply pathways:

Domestic dispatchable generation + Domestic variable generation + Imports



Domestic dispatchable

Balti and Eesti power plant: gone by 2030? Iru power plant: gone by 2023?



Domestic dispatchable

Expected peak load is slowly rising: 1564 MW in 2020 to 1717 MW in 2030



Domestic dispatchable

Capacity margin compared to peak demand from dispatchable generation is already negative. Dropping to -675 MW in 2023 and maybe -1 GW in 2030.



Ensuring security of supply

Simplified supply pathways:

Domestic dispatchable generation + Domestic variable generation + Imports



- Estonian variable renewable generation (wind and solar PV) is expanding. Expected to to be able to generate up to 1/3rd of annual demand by 2030.
- Elering (grid operator) assigns zero capacity credit to VRE, meaning they do not count toward security of supply. Is this reasonable going forward?

OC LTD



- At a VRE capacity equal to annual demand ("100% RE") or 1.5 times annual demand, what capacity credit could be assigned to VRE?
- How much additional *dispatchable* capacity is required to *domestically* cover security of supply?



OC LTD

Data

Study of 35 years weather data (1982 to 2017) for hourly capacity factors of solar and wind (resource adjusted with *modern technology*) and hourly load profiles adjusted for historic temperature conditions from ENTSO-E

Question

What is the biggest difference between VRE output and demand over a certain time period, stretching from a single hour to 4 weeks?

Follow-on study (not yet performed)

What is the frequency of occurrence (probability) of various VRE supply deficit events over different time periods?

How does the amount of required dispatchable capacity change with increasing levels of VRE capacity over time periods from 1 hour to 4 weeks?



Duration (hours)

Large scale storage

The EnergiaSalv project aims to have a 6 GWh / 500 MW pumped hydro storage plant in operation in Paldiski by 2028



Challenging weather week

All dispatchable power running (475 MW), storage fully charged (6 GWh), and an *optimized* VRE system large enough to supply 100 % of annual electricity needs (1.87 GW PV, 2.8 GW offshore wind).

• Still missing: 87 GWh of energy over the week, 958 MW of capacity!



Simulated weather week of 1996/01/17 to 1996/01/24

OC LTD

Baltic Integrated Power System

Very optimistic dispatchable capacity (3.4 GW), EnergiaSalv+Krounis fully charged (17 GWh), and 4900 MW of installed VRE capacity (ENTSO-E target for 2030)

• Still missing: 145 GWh of energy over the week, 1955 MW of capacity!



Simulated weather week of 1985/02/05 to 1985/02/12

OC LTD

Ensuring security of supply

Simplified supply pathways:

Domestic dispatchable generation + Domestic variable generation + Imports



Estonia Direct Imports

Future total interconnector capacity, once the third Latvia-Estonia cable is in operation, appears sufficient to cover import needs. Our statistical analysis predicts sufficient capacity available >99.7% of annual hours.



Interconnector capacity duration curve (based on hourly Nordpool data 2013-2020)

Importing security of supply

Baltic area disconnect from Russia (incl. Kaliningrad) and Belarus by end of 2025 means Baltic security of supply needs to be guaranteed by:

Northern routes: Norway + Sweden

Southern route: Germany + Poland



Importing security of supply?

Who has available export capacity? Power balance during stressed periods on both routes is negative already. On top of this:

- Norway is building large new interconnectors (UK, Germany etc.)
- Demand in Sweden and Norway set to increase dramatically (+30 to +70%)

OC LTD

Dispatchable capacity is closing (DE/SWE nuclear, PL/DE/FI/DK coal)



Start of February 2021

- Last days of available data No wind, relatively cold weather
- Nordic region total supply balance between -2 GW and -7 GW (!)
- Imports from Russia+Belarus, German coal+nuclear and Polish coal
- None of these import sources will be available longer term



Summary

- Estonian security-of-supply betting on imports is a very risky strategy
- Economic impacts are both short term (high costs, blackouts) and longterm (low willingness to invest or re-invest in industrial development)
- Import dependence on all time-scales makes the case new for domestic dispatchable low-carbon capacity, especially CHP for district heating cogeneration, extremely attractive
- Ideal opportunity for ~600 $MW_{\rm e}$ of SMR (CHP) capacity in the early 2030?





THE ESTONIAN POWER SYSYEM *Future Security of Supply*

Dr Staffan Qvist

staffanq@gmail.com 2021/02/09

